



ARTICLE 32: Groundwater Cons. District

ARTICLE 32: Groundwater Conservancy District

Mr. Sayegh moves:

That the Town take affirmative action on Article 32 as printed in the Warrant.

ARTICLE 32: Groundwater Cons. District

This Warrant Article changes Section 7.6.5.8 in the following manner:

7.6.5.8 On-site subsurface disposal which requires a minimum design flow under Title V in excess of four hundred and forty (440) gallons per day per ~~acre~~ **40,000 square feet.**

ARTICLE 32: Groundwater Cons. District

An acre = 43,560 square feet

Under Title V, an acre = 40,000 square feet

This proposed amendment will bring Section 7.6.5.8 of the Bylaw in conformance with Title V



ARTICLE 32: Groundwater Cons. District

ARTICLE 32: Groundwater Conservancy District

Mr. Sayegh moves:

That the Town take affirmative action on Article 32 as printed in the Warrant.