



CONCORD PUBLIC WORKS

Water and Sewer Division

135 KEYES ROAD

CONCORD, MASSACHUSETTS 01742

JEFFREY A. MURAWSKI
SUPERINTENDENT

TEL. : 978-318-3250
FAX. : 978-318-3204

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Concord Water had Levels of Bromate above Drinking Water Standards

The Town recently learned that drinking water provided from Nagog Pond during the summer of 2022 contained higher than allowable concentrations of bromate. Although this is not an emergency, as our customer, you have a right to know what happened, what you should do, and what we are doing to address this drinking water violation.

Currently, drinking water from Nagog Pond is only provided during summer months to help meet seasonal peak demand, and is disinfected with ozone to ensure that it is safe to drink. Nagog Pond water contains a naturally occurring trace element, bromide, which can react with ozone to form the by-product, bromate. The allowable concentration of bromate in drinking water, as a running annual average (RAA), is 0.010 milligrams per liter (mg/L). The quarter 3 monitoring period (July-September) resulted in a Nagog Pond bromate RAA of 0.011 mg/L. Nagog Pond produced water in July and August of 2022.

What should I do?

There is nothing you need to do. You **do not** need to boil your water or take other corrective actions. However, if you have specific health concerns, please consult your doctor.

What does this mean?

This **is not** an emergency. If it had been, you would have been notified within 24 hours. However, *some people who drink water containing bromate in excess of the MCL over many years have an increased risk of getting cancer.*

What is being done?

The Nagog Pond water supply was shut down for the season on August 24, 2022, and is anticipated to come back online during the summer of 2023. Concord Water staff continue to work with our consulting engineers and MassDEP to evaluate existing treatment practices in an effort to reduce bromate. Additionally, Concord Water has been working on the design and permitting of a new water treatment facility for Nagog Pond for several years. Permitting and legal challenges prevented the project from moving forward as quickly as we would like. Concord Public Works is continuing to advance the design and local permitting activities of the new water treatment plant so that we can continue to provide high quality drinking water to all our customers.

For more information, please visit www.concordma.gov/bromate or contact Concord Water and Sewer Division at 978-318-3250; 135 Keyes Rd, Concord, MA 01742.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.